

HI-TECH WATER SERVICES

215 South Brainard Avenue - LaGrange, IL 60525

Telephone: (708) 354-7445

Date 7/17/05

Time 9:50

WATER TREATMENT SERVICE REPORT

Firm Clean Air Eng Telephone _____

Address _____ City _____ State _____

Attention _____ Copies _____

Sample	Cooling Wtr.	Chilled WTR	Hot WTR			TAP	Control Limits
Field Test							
Total H							
CaH	500					140	450-550
P Alk.	72						
M Alk.	280						
OH Alk. 2P-M	0					0 = 70	
Chlorides	14					12-14	35-40
Phosphate							
Sulfite							
Chromate							
Conductance TDS MMHOS							
pH	8.6					8.4	8.5-9.5
Nitrite		1400	1800			8.0	6000-95
Iron							
Phosphate	0						

this is higher than target but OK

Submitted To _____

RECOMMENDATIONS <u>Adjusted Chem feed pump</u>		CHEMICAL INVENTORY	
		Product	Quantity

FIELD ENGINEER B. J. Cloninger